



Valley Water System # 4310027

Report for: Penitencia, Rinconada, Santa Teresa Water Treatment Plants

Start: 10/1/2021 End: 10/31/2021

Primary Standards - Mandatory Health-Related Standards

	Units	MCL	DLR	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated
Aluminum	ug/L	1000	50	111	ND	112	ND	ND	ND
Antimony	ug/L	6	6	ND	ND	ND	ND	ND	ND
Arsenic	ug/L	10	2	3	ND	3	ND	3	ND
Barium	ug/L	1000	100	ND	ND	ND	ND	ND	ND
Beryllium	ug/L	4	1	ND	ND	ND	ND	ND	ND
Bromate	ug/L	10	1	NT	2	NT	NT	NT	2
Cadmium	ug/L	5	1	ND	ND	ND	ND	ND	ND
Chlorine Total by DPD	mg/L	NS	NS	NT	3.2	NT	2.4	NT	3.2
Chromium	ug/L	50	10	ND	ND	ND	ND	ND	ND
Fluoride	mg/L	2	0.1	ND	0.7	ND	ND	ND	0.7
Mercury	ug/L	2	1	ND	ND	ND	ND	ND	ND
Nickel	ug/L	100	10	ND	ND	ND	ND	ND	ND
Nitrate as Nitrogen	mg/L	10	0.4	ND	ND	ND	ND	ND	ND
Nitrite as Nitrogen	mg/L	1	0.4	ND	ND	ND	ND	ND	ND
Perchlorate	ug/L	6	2	ND	ND	ND	ND	ND	ND
Selenium	ug/L	50	5	ND	ND	ND	ND	ND	ND
Thallium	ug/L	2	1	ND	ND	ND	ND	ND	ND
Dibromoacetic Acid	ug/L	NS	1	NT	5.1	NT	6.6	NT	2.6
Dichloroacetic Acid	ug/L	NS	1	NT	2.1	NT	3.1	NT	ND
Monobromoacetic Acid	ug/L	NS	1	NT	ND	NT	1.1	NT	ND
Monochloroacetic Acid	ug/L	NS	2	NT	ND	NT	ND	NT	ND
Trichloroacetic Acid	ug/L	NS	1	NT	3.1	NT	2.9	NT	ND
Total Haloacetic Acids (5)	ug/L	60	NS	NT	10	NT	14	NT	3
Bromodichloromethane	ug/L	NS	1	NT	7.8	NT	13.2	NT	4.4
Bromoform	ug/L	NS	1	NT	9.3	NT	12.1	NT	11.4
Chloroform	ug/L	NS	1	NT	4.9	NT	4.4	NT	ND
Dibromochloromethane	ug/L	NS	1	NT	14.8	NT	24.5	NT	10.7
Total Trihalomethanes	ug/L	80	NS	NT	37	NT	54	NT	27
Heterotrophic Plate Count	CFU/mL	NS	NS	7936	1	6314	1	2895	<1

Secondary Standards - Aesthetic Standards

	Units	MCL	DLR	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated
Apparent Color	Color Unit	15	NS	28	<2.5	28	<2.5	25	<2.5
Chloride	mg/L	500	NS	103	106	100	101	89	92
Conductivity	umhos/cm @ 25C	1600	NS	566	643	565	624	585	635
Copper	ug/L	1000	50	ND	ND	ND	ND	ND	ND
Iron	ug/L	300	100	122	ND	131	ND	ND	ND
Manganese	ug/L	50	20	22	ND	34	ND	110	ND
pH	pH units	NS	NS	8.2	7.8	8.3	7.7	8.0	7.9
Silver	ug/L	100	10	ND	ND	ND	ND	ND	ND
Sulfate	mg/L	500	0.5	26.5	59.4	29.8	64.2	44.4	64.1
Total Dissolved Solids at 180C	mg/L	1000	NS	300	352	298	346	324	356



Valley Water System # 4310027

Report for: Penitencia, Rinconada, Santa Teresa Water Treatment Plants

Valley Water
Clear Water • Healthy Environment • Proud Protection

Start: 10/1/2021 End: 10/31/2021

Turbidity	NTU	5	0.1	3.30	ND	3.48	ND	2.48	ND
Zinc	ug/L	5000	50	ND	ND	ND	ND	ND	ND

Additional Constituents Analyzed

	Units	MCL	DLR	PWTP Influent	PWTP Treated	RWTP Influent	RWTP Treated	STWTP Influent	STWTP Treated
Boron	ug/L	NS	100	186	169	185	174	215	214
Bromide	mg/L	NS	NS	0.36	0.20	0.35	0.17	0.29	0.20
Calcium	mg/L	NS	NS	20.9	19.3	22.3	21.3	29.9	29.8
Chlorate	ug/L	NS	20	NT	108	NT	112	NT	216
Hexavalent Chromium	ug/L	NS	1	ND	ND	ND	ND	ND	ND
Lead	ug/L	NS	5	ND	ND	ND	ND	ND	ND
Magnesium	mg/L	NS	NS	16.6	15.2	16.1	15.3	17.6	17.5
Phosphate, Ortho (as PO4)	mg/L	NS	NS	0.31	0.96	0.29	1.02	0.27	0.89
Potassium	mg/L	NS	NS	4.7	4.4	4.6	4.3	4.7	4.8
Sodium	mg/L	NS	NS	80	92	77	88	76	88
Temperature	Deg C	NS	NS	19	19	19	19	20	20
Total Alkalinity (as CaCO3)	mg/L	NS	NS	79	72	82	69	96	92
Total Ammonia Nitrogen	mg/L	NS	NS	<0.1	0.90	<0.1	0.59	<0.1	0.86
Total Organic Carbon	mg/L	NS	0.3	4.10	2.20	4.07	1.87	4.07	2.10
Vanadium	ug/L	NS	3	4	4	5	ND	4	ND

MCL = Maximum Contaminant Level
 DLR = Detection Limit for Reporting
 PWTP = Penitencia Water Treatment Plant
 RWTP = Rinconada Water Treatment Plant
 STWTP = Santa Teresa Water Treatment Plant

mg/L = milligrams per liter
 ug/L = micrograms per liter
 Deg. C = Degree Celsius
 CFU/mL = colony forming units per milliliter
 umhos/cm = micromhos per centimeter
 NTU = nephelometric turbidity units

ND = Not Detected
 NT = Not Tested
 NS = No Standard
 NR = Not Reported

For questions about this report, or for additional water quality information, call (408) 630-2268.

Surjit Saini
 Laboratory Manager
 Laboratory Services Unit

11/09/2021

MONTHLY SUMMARY OF REVISED TOTAL COLIFORM RULE DISTRIBUTION SYSTEM MONITORING

(For public water systems serving more than 400 service connections OR 1,000 persons, OR wholesaler systems)
 (Includes triggered source monitoring for Groundwater Rule compliance)

System Name: Santa Clara Valley Water District	System Number: 4310027
Sampling Period: Month: October	Year: 2021

	Number Required	Number Collected	Number Total Coliform Positives	Number E.Coli Positives
1. Routine Samples (see note 1) :	<u>340</u>	<u>400</u>	<u>0</u>	<u>0</u>
2. Repeat Samples following samples that are Total Coliform POSITIVE and E.coli NEGATIVE (see notes 2, 10 and 11) :		<u>0</u>	<u>0</u>	<u>0</u>
3. Repeat Samples following routine samples that are Total Coliform POSITIVE and E. coli POSITIVE (see notes 2, 3, 10 and 11) :		<u>0</u>	<u>0</u>	<u>0</u>
4. Coliform Treatment Technique (TT) Trigger Exceedance % and E.coli /MCL Computation for Total Coliform/E.Coli Positive Samples				
a. Totals (sum of columns) :	<u>340</u>	<u>400</u>	<u>0</u>	
b. If 40 or more samples are collected in the month, determine percent of samples that are Total Coliform positive. ([total number positive / total number collected] x 100):	<u>0.00</u>	%		
c. Did the system violate the E.coli MCL (see note 2 through 5)?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Did the system trigger... a LEVEL 2 Assessment TT?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
(See notes 2, 3, 4 ,5 and 6 for trigger info)				
If Yes, see note 8 below.				
... a LEVEL 1 Assessment TT?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
(See notes 7 for trigger info)				
If Yes, see note 9 below.				
5. Triggered Source Samples per Groundwater Rule (see notes 12 and 13)		<u>0</u>	<u>0</u>	<u>0</u>
6. Invalidated Samples (note what samples, if any, were invalidated; why they were invalidated; who authorized the invalidation; and when replacement samples were collected. Attach additional sheets, if necessary.)				

7. Summary Completed By:

Name/Signature: 	Title: Surjit Saini Laboratory Manager	Date: 11/4/2021
---------------------	--	---------------------------

NOTES AND INSTRUCTIONS:

1. Routine samples include:
 - a) Samples required pursuant to 22 CCR Section 64423 and any additional samples required by an approved routine sample siting plan established pursuant to 22 CCR Section 64422
 - b) Extra samples for systems with high source water turbidities that are using surface water or groundwater under direct influence of surface water and do not practice filtration in compliance with regulations;
- Notes 2-5 (boxed entries) are E. coli MCL violations and require immediate notification to the Division (22 CCR, Section 64426.1):**
2. Any E.coli positive repeat following a total coliform positive sample.
3. NA total coliform positive repeat, following an E.coli positive routine sample.
4. Failure to take all required repeat samples following an E. coli positive routine sample.
5. Failure to test for E. coli when any repeat sample tests positive for total coliform
6. Note: Second Level 1 treatment technique trigger in a rolling 12-month period.
- 7. Level 1 Coliform Treatment Technique (TT) Triggers:**
 - a. For systems collecting less than 40 samples, if two or more samples are total coliform positive, then the TT is violated and a Level 1 Assessment is required
 - b. For systems collecting 40 or more samples, if more than 5.0 percent of samples collected are total coliform positive, then the TT is violated and a Level 1 Assessment is required.
 - c. If a trigger is exceeded as a result of a total coliform positive repeat sample, the system must notify the Division by the end of business day, section 64424(c)**
8. Contact the Division as soon as practical to arrange for the division to conduct a Level 2 Assessment of the water system. The water system shall complete a Level 2 Assessment and submit it to the Division within 30 days of learning of the trigger exceedance.
9. Conduct a Level 1 Assessment in accordance with as soon as practical that covers the minimum elements (22, CCR, Section 64426.8 (a), (2). Submit the report to the Division within 30 days of learning of the trigger exceedance.
10. Positive results and their associated repeat samples must be tracked on the Coliform Monitoring Worksheet
11. Repeat samples must be collected within 24 hours of being notified of the positive results. . At least 3 repeat samples must be collected for each total coliform positive sample.
12. For systems subject to the Groundwater Rule: Positive results and the associated triggered source samples are to be tracked on the Coliform Monitoring Worksheet.
13. For triggered sample(s) required as a result of a total coliform routine positive sample, an E.coli positive triggered sample (boxed entry) **requires immediate notification to the Division, Tier 1 public notification, and corrective action.**